





- ## **NOTES:**
- ALL WORKS TO BE DONE ACCORDING TO SANS 1200
  - NEW WALL EXTENSION LEVELS TO BE SIMILAR TO EXISTING
  - ANY DISCREPANCIES TO BE COMMUNICATED TO THE ENGINEER PRIOR TO COMMENCEMENT OF THE WORKS
  - DAM FLOOR LEVELS TO BE CONFIRMED AND LEVELS TO BE SENT TO ENGINEER PRIOR TO COMMENCEMENT OF CONSTRUCTION
  - CONCRETE GRADE TO BE AS FOLLOWS
    - STRUCTURAL CONCRETE GRADE 30MPa/19mm
    - MASS CONCRETE 20MPa/19mm
    - BLINDING 15MPa/19mm



All dimensions must be verified on site before the work.  
Refer any discrepancies to the Engineer.

Copyright reserved

— — — — —

31 Allen Drive | Loevenstein | Cape Town | 7530  
Tel: +27 (0) 21 912 3000 | Fax: +27 (0) 21 912 322  
[www.ixengineers.co.za](http://www.ixengineers.co.za)

KAREEBERG LOCAL  
MUNICIPALITY

# UPGRADING OF CARNARVON OXIDATION PONDS

ANAEROBIC POND -  
LAYOUT AND DETAILS  
SHEET 2 OF 2

